



REPLY TO
ATTENTION OF

DEPARTMENT OF THE ARMY
FORT WORTH DISTRICT, CORPS OF ENGINEERS
P. O. BOX 17300
FORT WORTH, TEXAS 76102-0300

August 29, 2003

Contracting Division

Planholders:

1. Reference is made to Solicitation No. DACA63-03-B-0006, Consolidated Wing Support Facility, Goodfellow Air Force Base, San Angelo, Texas.
2. Enclosed are answers to contractor questions that were submitted to this office for the referenced solicitation.
3. This enclosure is for information purposes only and is not a part of the Invitation For Bid.

Sincerely,

A handwritten signature in cursive script that reads "Shelley A. Martinez".

Shelley A. Martinez
Contract Specialist

Enclosure

Consolidated Wing Support Facility, Goodfellow Air Force Base, San Angelo, Texas

DACA63-03-B-0006

Q: On sheet C-115 note 5 for the sectionalizing switch, refers you to detail 2 on sheet C-115 and detail 7 on sheet C-517, by what I can see and by what my suppliers are telling me these are two different type of sectionalizing switch's. Which of the two details do we use in determining the type of sectionalizing switch we are to provide.

A: Reference Drawing Sheet C-115, Detail 2: Delete the 500 amp fuses on the incoming service from the transition pole and the outgoing feeder to existing Manhole No. 3. This sectionalizing switch shall be fused as indicated on the two other feeders.

Q: Is this project exempt from Federal, State and Local taxes?

A: The project is not exempt from taxes. Please refer to Section 00700, Page 40, FAR 52.229-3.

Q: Is a Small Business Subcontracting Plan due at bid time?

A: Small Business Subcontracting Plan is required prior to award but not at bid opening. Please refer to Section 00100, Page 2.