

2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 21 APR 99	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
---------------------------------------	--------------------------------	----------------------------------	--------------------------------

6. ISSUED BY  Department of the Army Corps of Engineers Fort Worth District	7. ADMINISTERED BY (If other than Item 6)
---	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(√)	9A. AMENDMENT OF SOLICITATION NO. DACA63-99-B-0012
	(X)	9B. DATED (SEE ITEM 11) 19 MARCH 1999
		10A. MODIFICATION OF CONTRACTS/ORDER NO.
		10B. DATED (SEE ITEM 13)

CODE	FACILITY CODE	<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>
------	---------------	--

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers  is extended,  is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  
 (a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

(√)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

**E. IMPORTANT:** Contractor  is not,  is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)  
 The Solicitation for PRIMARY CARE FACILITY, FORT HOOD, TEXAS, is amended as follows:

See Continuation Sheet.

NOTE: The Bid Opening date remains "27 April 1999, 2 p.m.", as previously announced.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)	15C. DATE SIGNED
	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)
	16C. DATE SIGNED

Item 14. (Cont'd)

Drawings:

- 1) Sequence No. 165 (sheet E2.3)
  - a) Add music only speaker to room A024
  - b) Delete room status switch from room A024
  - c) Change the ceiling speakers to music only type in rooms A005 and A007
- 2) Sequence No. 168 (sheet E2.6) – Change speaker volume control in room A121 to “VR” instead of “V” type. Speaker should be part of zone 9.
- 3) Sequence No. 171 (sheet E2.9) –
  - a) Delete public address desk microphone from room A160
  - b) Change subscript of room status symbol from “L” to “ZL”
- 4) Sequence No. 174 (sheet E2.12) - Room A164, Change room status symbols with subscripts “EL” and “LL” to “ZL”.
- 5) Sequence No. 165 (sheet E2.3) – Nurse call symbol over door to room B065 should be “EL” instead of “ET”.
- 6) Sequence No. 180 (sheet E2.18) - Change speaker volume control in room B132 to “VR” instead of “W” type. Speaker should be part of zone 5.
- 7) Sequence No. 161 (sheet E1.1) – Add room status symbol with a subscript “ZL” to the symbols legend. This symbol is a zone light.
- 8) Sequence No. 182 (sheet E3.1) – Add speaker and volume control to zone 11 of the schematic.
- 9) Sequence No. 094(sheet A8.6) – Title for Detail 13 should read “TYPICAL WORK AREA B052”

Specifications:

- 1) Section 16761, Room Status System
  - a) 1.6.1.b - Add a comma (,) after “locations” and add the following “at zone lights at end of corridors.”.
  - b) 1.6.3 – After “Corridor Indicator Lights” add “Zone Lights”.
  - c) Add paragraph 1.7.7. Zone Lights – Zone lights shall be identical to corridor lights except that lights shall be wall mounted where shown on drawings.
  - d) 2.3 – Change paragraph title from “CORRIDOR DOME LIGHTS” to “CORRIDOR DOME LIGHTS AND ZONE LIGHTS”. In the first paragraph after “Corridor dome light” add “and zone light”.